



NMSU FIRE DEPARTMENT FIRE PUMPS MONTHLY INSPECTION



This form covers a 1-year period. Year: _____

Inspector: _____

System: _____

Location: _____

Y=Satisfactory N=Unsatisfactory (explain on reverse) N/A = Not applicable

Monthly

Date												
Inspector												
Remove battery corrosion; clean and dry battery.												
Check battery charger and charger rate.												
Equalize charge in battery system.												
Exercise isolating switch and circuit breaker.												
Inspect, clean, and test circuit breakers.												

Notes: _____

See Main System Record of Completion for additional information, certifications, and approvals. Attach additional sheets, data, or calculations as necessary to provide a complete record.

Form Completion Date: _____

Supplemental Pages Attached: _____