

Facilities and Services 2015 Fall Semester Light Tour

December 3, 2015

Work order to the Electric shop for repairs to the following existing exterior lights found to be not working during the walk.

- Gardiner Hall Exterior lights. Check control and Function
- Knox Hall south east 2 wall lights out
- Jett Hall west entrance 2 lights out
- Science Hall clock structure 3 lights out (Ameresco)
- Thomas & Brown South Entrance 2 lights out
- Computer Center Court Yard 1 pole light out
- Computer Center N/NE door light
- Astronomy North Entrance 2 lights out
- Zuhl Library several lights out on short Poles
- Corbett Parking lot 17 2 lights out (blinking)
- Milton East Entrance 2 lights out
- Jordan Street across from B&N one light pole out. Will change all 4 poles on Jordan Street to LED fixtures to match Parking lot and for better light levels.
- Tree uplight at west end of bookstore row along University (west of Panda)
- Street lights at Corbett center parking lot
- Roberts Hall North Entrance
- Up light for tree at B&N
- New LED streetlight out in B+N parking lot near the English/Speech building (SW corner of B+N parking lot (reported to Matt at RTS)
- Three LED lamps in the bollards are out at EC III (reported to Matt at RTS)
- Police chief was asking about the Verizon pole at NE corner of Milton Hall; Stephen will ask Ben Woods about this. This street light was not working (not part of Ameresco contract)
- Replace burned out lights at Knox Fountain.

Work order to Grounds to address the items identified during the light walk.

- Bio-Chemistry fountain needs to be shut down for winter.
- Remove sign pole along sidewalk between Music and Bio-Chemistry.
- Trim trees above Thomas and Brown entrance.
- Trim Mexican elder branches up between Walden Hall and New Science.
- Trim branches by light pole at North Milton Hall.
- Repair rock wall northeast of Business Complex. Lot 13; remove two poles.

Additional Lighting needed per consensus of the group that will require lead time to order materials and or additional funding and will be prioritized accordingly.

- New Lights under soffit along North side of Science Hall
- New Lights along north west walkway of EC2 /3
- New small light pole at Astronomy north entrance
- Change out single arm light poles to double arm at several parking lots locations for more light (lots 57 and 54)
- Retrofit Zuhl Parking Lot 45 to LED for better light
- Jordan Street across from B&N add new light pole as close to intersection as possible for better light at cross walks
- Walkway between Zuhl and Milton, turn existing poles 180 degrees or add second fixture to light sidewalk better
- Check all major Pedestrian cross walks (Espina & Frenger) for need to add lighting or light pole for better light levels
- The Horseshoe grassy area under the big trees on the west side we discussed landscape lighting on the trees

Facilities and Services 2015 Fall Semester Light Tour December 3, 2015

- outside of the west side entrance door to Jett Hall was pretty dark
- The cross walk on Espina at Frenger hard to see someone walking across the street
- A double armed pole on Sweet St. at Lot 57 would add lighting in the parking lot west side
- There is a dark spot just to the east of Dr. Milton's statue at the Milton Hall entrance under the cork trees
- NW corner of New Science Hall, up close to the building
- West wall of Jett Hall, over entrances
- SW corner of Jett Hall, just outside the south entry doors
- Espina crosswalk at South Horseshoe
- In general, street lights are rarely located where crosswalks exist. For example, along Espina, most crosswalks are dark while the spaces in between have street lighting.
- Biology Annex south parking lot, especially along the north sidewalk. This could probably be alleviated by adding a north arm to the existing Stewart St. pole.
- Astronomy Bldg. north side: dark place around the transformer yard and under the trees in the front of the building.