



NMSU FIRE DEPARTMENT FIRE PUMPS ANNUAL MAINTENANCE



Inspector: _____

System: _____

Location: _____

Satisfactory	Unsatisfactory	
		Lubricate pump bearings.
		Lubricate coupling.
		Lubricate right-angle gear drive.
		Grease motor bearings.
		Replace flexible hoses and connector.
		Replace oil at 50 hours or annually.
		Replace oil filter at 50 hours or annually.
		Calibrate pressure switch settings.
		Check accuracy of pressure sensors.
		Clean pump room louvers.
		Remove water and foreign material from diesel fuel tank.
		Rod out the heat exchanger or cooling system.
		Fire pump controller in service.
		Jockey pump controller in service.
		Fire alarm panel "normal."

Notes: _____

See Main System Record of Completion for additional information, certifications, and approvals. Attach additional sheets, data, or calculations as necessary to provide a complete record.

Form Completion Date: _____

Supplemental Pages Attached: _____