



NMSU FIRE DEPARTMENT FIRE PUMPS MONTHLY AND SEMI-ANNUAL TESTS



This form covers a 1-year period. Year: _____

Inspector: _____

System: _____

Location: _____

Y=Satisfactory N=Unsatisfactory (explain on reverse) N/A = Not applicable

Monthly

Date													
Inspector													
Exercise isolating switch and circuit													
Test antifreeze to determine protection level.													
Test batteries for specific gravity or state of charge.													
Test circuit breakers and fuses for proper operation.													

Semi-Annually

Date													
Inspector													
Operate manual starting means.													
Operate safety devices and alarms.													

Notes: _____

See Main System Record of Completion for additional information, certifications, and approvals. Attach additional sheets, data, or calculations as necessary to provide a complete record.

Form Completion Date: _____

Supplemental Pages Attached: _____